

Main Features

- The compact design enables installation in a narrow space (can be replaced with an SS type on 1:1 basis)
- Accurate display of operating current via the frontal LED display (the higher current value will be displayed, whichever is higher between L1 and L3)
- · LED window displays the trip cause when a trip occurs
- · Accurate phase loss protection (3 sec)
- Easy application: Can select between single-phase (1P) or 3-phase (3P) using DIP SW.
- Works well with an inverter system: 20~200Hz
- Can select contact output[Fail safe(N)/Non-fail safe(R)]: Maximum convenience for sequence configuration
- · Easy installation, with DIN Rail and Panel Mounting compatibility

Protection Function

rotection Function	Operation Time
Over Current	Operates after O-Time
Phase Loss	Operates within 3 sec
Locked Rotor	Immediately operates if 200% or more of the set current continues after D-Time

Trip Cause Display and Check Method

		Operation Display (Trip Indication)	
Trip Cause	Trip Cause Display	Description	
Over Current	o 10.0°	Trips after detecting the over current of 10A during operation.	
	PE-1-	Trips by L1 (R) phase loss.	
Phase Loss	PL-2	Trips by L2 (S) phase loss.	
	PL-3	Trips by L3 (T) phase loss.	
Locked Rotor	-12-	Trips when a stall is detected.	



Specifications

Functions and Characteristics			Specifications				
Current Setting	Over Current	5	0.5~6A				
		30	3~30A				
		60	10~60A				
		60A or higher	Use 05Type in combination with an external CT				
Time Setting	Start Delay Time	D-Time	1~30 sec				
	Operation Time	O-Time:	0.5/1~10 sec				
Reset			Manual(instant) reset/electrical reset (power supply cut)				
Operation Time Characteristic	Over Current		Definite				
Error Tolerance	Current		±5%				
	Time		±0.2 sec				
Usage Environment	Temperature	Operation	-20°C~60°C				
		Storage	-30°C~80°C				
	Humidity		30~85% RH without icing				
Operating Power Supply	24		AC/DC24V				
	110		AC110V±15%, 50/60Hz				
	220		AC220V±15%, 50/60Hz				
	440		AC440V±15%, 50/60Hz				
Output contact	2-SPST (1a1b)		AC250V/3A resistive load				
Insulation	Resistance	Between circuit and case	10MQ at DC500V				
,	Withstanding Voltage	Between circuit and case	2,0kV, 60Hz for 1 min				
		Between contacts	1.0kV, 60Hz for 1 min				
		Between circuits	2.0kV, 60Hz for 1 min				
Attachment Method			35mm DIN Rail or Panel				
Electrostatic Discharge	IEC61000-4-2	Level 3:	Air Discharge: ±8kV				
			Contact Discharge: ±6kV				
Radiated Electromagnetic	IEC61000-4-3	Level 3:	10V/m, 150MHz & 450MHz				
Field Disturbance			Portable Transceiver				
EFT/Burst	IEC61000-4-4	Level 3:	±2KV, 1 Min				
Surge	IEC61000-4-5	Level 3:	1.2×50µs, ±4kV(0°, 90°, 180°, 270°)				
Conducted Disturbance	IEC61000-4-6	Level 3:	10V, 0.15~80MHz				
1MHz Burst Disturbance	IEC61000-4-12	Level 3:	2.5kV, 1MHz				
Conducted Emission	EN55011	Level 3:	Class A (Conducted & Radiated)				

Function Setting Sequence and Settings Menu

. Configure the setting as follows before operating the motor:

- 1. Operating Current Setting
- Set it on the motor's rated current, but in order to protect the machine as well as the load, check the active load current with the digital indicator under normal load state after the startup is complete, and set it to be higher (110%~125%) than the operating current by turning the LOAD knob.
- 2. Start Delay Time
- ① Set it to max and start the motor.
- ② After starting the motor, check the current while measuring the time it takes for the operating current to return to normal current. Set the start delay time to about 1 sec longer than the measured time using the D-TIME knob. (For Y-\Delta startup, set it to 1~2 sec longer than the full start timer)
- 3. Operating Time: Set the time it takes for the relay to operate from the moment the current flow exceeds the current set value using the O-TIME Knob.

Sequence	Items	Display	Setting Method	Notes
1	Over Current Setting	c 30:	05 Type : 0.5A~6A 30 Type : 3A~30A 60 Type : 10A~60A	0.5~6A: Changes in increments of 0.1A 3~30A: Changes in increments of 1A 10~60A: Changes in increments of 1A
2	Start Delay Time Setting	d 10.	1~30 sec	Changes in increments of 1 sec
3	Over Current Operation Time Setting	o 10.	0.5, 1~10sec	0.5sec 1~10 sec (Changes in increments of 1sec)
4	TEST Function	7857.	After 3 sec + set O-Time is elapsed, displays END	After 3 sec + set O-Time, during operation.



TEST Function


Each set value and the health status of the relay can be checked by pressing the TEST button.

Before the motor starts		After the motor starts
The set value for each setting mode can be checked each time the TEST button is pressed. Test function is completed after going through the TEST mode, which checks the set values and inspects the health status of the EOCR itself.		Each time the TEST button is pressed, the set value for each setting mode can be checked.
↓ RESET) pressed	Current Display Displays higher current value between L1 and L2 Before startup: In=0A, after startup: In=3.85A	385° ↓ TEST pressed
☐ ☐ ☐ · · · · · · · · · · · · · · · · ·	<u>Current Setting Mode</u> Current Setting (ls)=4.5A	€ 4.5 ·
☐ ☐ .	Start Delay Time (D-TIME) Setting Mode D-TIME=10 sec	☐ ☐ .
© 5.	Operation Time (O-TIME) Setting Mode O-TIME=5 sec	g 5.
TEST 3 sec + set O-Time elapsed	Self-TEST begins	Does not perform in Relay Test mode in order to prevent a trip accident during operation.
Eng ↓ RESET) pressed	Self-TEST in progress Self-TEST completed After setting O-TIME, the contact of inner Relay is passed and the self-TEST is completed.	Returns to operating current display mode after 10~20 sec in any mode
0.00	Returns to current display mode if the Reset button is pressed	3.85





Over Current Operation Time Characteristic Curve

Example Wiring Diagram











I/O (Input/Output) Terminal Diagram



Dimensions Diagram





Ordering Specifications

pear between a			Current Range	Output	Operating F	ower Supply	
н	eference		[A]	Contact	Voltage [V]	Frequency [Hz]	Notes
	EOCRSSD	-05DB	5	b-a	DC/AC 24V	-	-
		-30DB	30	b-a	DC/AC 24V	-	
		-60DB	60	b-a	DC/AC 24V	-	
		-05DF7	. 5	b-a	AC 110V	50/60	- A-
		-30DF7	30	b-a	AC 110V	50/60	
		-60DF7	60	b-a	AC 110V	50/60	<u> </u>
		-05DM7	5	b-a	AC 220V	50/60	
		-30DM7	30	b-a	AC 220V	50/60	
		-60DM7	60	b-a	AC 220V	50/60	
		-05DR7	5	b-a	AC 440V	50/60	-
		-30DR7	30	b-a	AC 440V	50/60	
		-60DR7	60	b-a	AC 440V	50/60	343
		-D1DB	100:05:00	b-a	DC/AC 24V	A .	Rectangular CT Combinatio
		-DHDB	150:05:00	b-a	DC/AC 24V		Rectangular CT Combination
		-D2DB	200:05:00	b-a	DC/AC 24V	<u></u>	Rectangular CT Combination
335		-D3DB	300:05:00	b-a	DC/AC 24V	-	Rectangular CT Combination
DOD.	97	-D4DB	400:05:00	b-a	DC/AC 24V	-	Rectangular CT Combination
		-D1DF7	100:05:00	b-a	AC 110V	50/60	Rectangular CT Combination
EOCR-SSD		-DHDF7	150:05:00	b-a	AC 110V	50/60	Rectangular CT Combination
		-D2DF7	200:05:00	b-a 🁝	AC 110V	50/60	Rectangular CT Combination
		-D3DF7	300:05:00	b-a	AC 110V	50/60	Rectangular CT Combination
		-D4DF7	400:05:00	b-a	AC 110V	50/60	Rectangular CT Combination
		-D1DM7	100:05:00	b-a	AC 220V	50/60	Rectangular CT Combination
		-DHDM7	150:05:00	b-a	AC 220V	50/60	Rectangular CT Combination
		-D2DM7	200:05:00	b-a	AC 220V	50/60	Rectangular CT Combination
		-D3DM7	300:05:00	b-a	AC 220V	50/60	Rectangular CT Combination
		-D4DM7	400:05:00	b-a	AC 220V	50/60	Rectangular CT Combination
		-D1DR7	100:05:00	b-a	AC 440V	50/60	Rectangular CT Combination
		-DHDR7	150:05:00	b-a	AC 440V	50/60	Rectangular CT Combination
		-D2DR7	200:05:00	b-a	AC 440V	50/60	Rectangular CT Combination
		-D3DR7	300:05:00	b-a	AC 440V	50/60	Rectangular CT Combination
	4	-D4DR7	400:05:00	b-a	AC 440V	50/60	Rectangular CT Combinatio

How to Order

To order an EOCR-SSD:

E	0	C	R	S	S	D	-	0	5	D	M	7
		-			100							

		5	0.5~6A
Current Range	Current Range	30	3~30A
		60	10~60A
9	Output Contact State	D	b (95-96), a (97-98)
		В	AC/DC24V compatible
	Operating Power Supply/ Frequency	F7	AC110V, 50/60Hz
0		M7	AC220V, 50/60Hz
		R7	AC440V, 50/60Hz

^{**} For a CT combination type, please write an accessory code from the CT Order Codes separately.